

THE BRAITHWAITE BURN & JESSOP CONSTRUCTION CO LTD.
NIT/DGM(P-II)/SB/FIRE EXTINGUISHER/HEAD OFFICE & HEAVY
PLANT YARD DT. 09.05.2012

(A GOVERNMENT OF INDIA UNDERTAKING &SUBSIDIARY OF BHARAT BHARI UDYOG
NIGAM LTD.)
27, R.N. MUKHERJEE ROAD, KOLKATA – 700 001

1.	TENDER NOTICE NO.	NIT/DGM(P-II)/SB/FIRE EXTINGUISHERHEAD OFFICE & HEAVY PLANT YARD
2.	DATE	09.05.2012
3.	SCOPE OF WORK/CONTRACT	REFILLING/REPLACEMENT OF EXISTING FIRE EXTINGUISHERS INSTALLED BOTH AT OUR HEAD OFFICE 27, R.N. MUKHERJEE ROAD, (1 ST & 2 ND FLOOR) AND AT OUR HEAVY PLANT YARD P-82, TARATOLLA ROAD, GARDEN REACH KOLKATA – 700 024
4.	PERIOD OF COTNRACT	FOR ONE YEAR
5.	DATE OF ISSUE OF TENDER	BETWEEN 09.05.2012 TO 22.05.2012
6.	TIME AND LAST DATE OF SUBMISSION OF TENDER	UPTO 12 HRS on 23.05.2012
7.	DATE OF OPENING	ON 23.05.2012 at 3.00 P.M.

(S. BANERJEE)
DY. GENERAL MANAGER(P-II)

THE BRAITHWAITE BURN & JESSOP CONSTRUCTION CO LTD

INSTRUCTION TO BIDDERS

1. **Submission of Bid:** All the pages of the tender document to be signed with Company's seal by the bidders. The rates in the appropriate space in the **BILL OF QUANTITY** should be properly filled, both in figures and words. No overwriting, using of correction fluid will be allowed. Any correction will be done by scoring out the incorrect entry and inserting the new entry in a legible manner. Both the correction and new entry to be signed and sealed with Company's seal. In the event of any difference between figure & words of the quoted rates, the rate in word shall be considered for evaluating the tender.
2. The bidder must fill the **BILL OF QUANTITY** (vide BOQ-1) with the appropriate column being duly filled-in, signed and sealed.
3. Conditional tenders shall be straightway rejected and no additional clause will be entertained.
4. BBJ administration reserves the right to accept/reject any or all of the tenders and split the scope of work to more than one agency/agencies without assigning any reason whatsoever. No claim will be entertained on account of this.
5. All duties, taxes, fees and other levies payable by the Agency under the contract or any other cause shall be included in the quoted price.
6. Validity of Tender – 90 days from the date of opening of tender or for a further period if mutually accepted.

THE BRAITHWAITE BURN & JESSOP CONSTRUCTION CO LTD

SPECIAL CONDITIONS OF CONTRACT

1. **SCOPE OF WORK:**
 - (i) To carry out complete refilling work and replacement of cylinders if necessary both at our Head Office and Heavy Plant Yard.
 - (ii) Prompt and efficient service on part of the Agency in respect of the above is necessary.
 - (iii) The bidders should visit at our both at our Head office and Heavy Plant Yard to inspect before quoting the rate.
2. **DURATION OF THE CONTRACT:**

For a period of one year from the date of refilling/replacement will be done.
3. **RATE:**

The rate should include all taxes and duties applicable during the tenure of the tender.
4. **PAYMENT TERMS:**

After 30 days from the date of refilling/replacement of cylinders and submission of bill duly certified.
5. **TERMINSTION OF CONTRACT:**

In case of failure to discharge the duties as per our requirement, BBJ reserves the right to cancel the order, either in part or full as the situation demands and get the work done by deploying other agency/agencies. Cost incurred for the above shall be recovered the agency's bill.

THE BRAITHWAITE BURN AND JESSOP CONSTRUCTION CO.LTD.
NIT/DGM(P-II)/SB/FIRE EXTINGUISHER/HEAD OFFICE & HEAVY PLANT
YARD DT. 09.05.2012

BOQ-1

BILL OF QUANTITIES

Sl.No.	Item	Qty(Nos.)	Rate/ Cylinder(Rs)	Amount(Rs.)
1.	a) Refilling of following existing Fire Extinguishers for Heavy Plant Yard(with proper certification):			
	i) Dry Chemical Powder Type – 05 KG Cyl ((IS2171-Yr.1999)	05 Nos.		
	--10 KG Cyl (IS2171-Yr.1999) (For Electrical fire)	02 Nos.		
	ii) Mechanical Foam Type (AFFF)-m09 litres (IS10204-Yr.2001) (For oil,fire diesel,petrol)	02 Nos.		
	iii) Water CO2 Type-09 lirs (IS940-Yr.2003)	05 Nos.		
	b) New Installation for Heavy Plant Yard:			
	i) Dry Chemical Powder Type – 10 KG Cyl (IS2171-Yr.1999) (For Electrical fire)	02 Nos.		
	ii) Water CO2 Type-09 litres (IS 940-Yr.2003) (For general fire stationery etc.)	01 No.		

2.	a) Refilling of following existing Fire Extinguishers installed at Head Office(with proper certification): i) Co2 – 2kgs capacity (IS:2878-Yr 2004) ii) Water CO2 Type – - 9 Ltrs. Capacity (IS:940-Yr 2003) ii) Dry Chemical Powder - 5 kgs capacity –for Electrical fire - (IS:2171-Yr 1999)	02 Nos.		
		04 Nos.		
		01 No.		

(S. BANERJEE)
DGM(P-II)

N.B.: Suppliers are to comply the following documents which are related to maintaining of ISO NORMS.

- a) After refilling/replacement **“CERTIFICATE OF FITNESS”** along with duration of good working condition to be handed over to us.
- b) Letter/Certification/Confirmation to be given, for providing the materials are as per above **IS CODIFICATION**.